





Presjek A-A




Regulacijska kliznih grla vijcima M12x25

Koalescentni uložci



Polipropilenski koalescentni uložak



Separatori spadaju u I. klasu separatora prema hrvatskoj normi HRN EN 858 što znači da je količina rezidualnog ulja manja od 5 mg/l

Volumen separatora: 30000 l
 Protok separatora: 125 l/s
 Cijevi: Ø500
 Masa praznog separatora: 5650kg
 Masa punog separatora: 30000kg

BIOGRAD NA MORU

Površina	Mjerilo	1:50	Pozicija	-	Masa	-
		- EN 858				

Ime	Datum	Polis
Levačić Ladislav, str.		Separator 30000
Horvat D. mag.ing. mech.		Q=125 lit/sec
Horvat Dž. str. inž. sec.		
Čičak		
Prekontl.		
Odobrio		



TX-DK-D-1907-SEP-30000-S1

radnji	Promjena	Datum	Ime	Spremljeno	TX-DK-D-1907-SEP-30000-S1